

Home Fire Safety Inspection



Horry County Fire Rescue

Community Safety Guideline

Easy Steps to Completing a Home Fire Safety Inspection

Over 97% of the fire fatalities experienced in the United States occur in single-family and multi-family dwellings. Additionally, fires in these same dwellings account for over 90% of all fire related injuries. Unfortunately, the place where all these fatalities and injuries occur is the only place your local fire department cannot inspect, your home. Knowing this, Horry County Fire Rescue encourages you to take it upon yourself to safeguard your family and perform a fire safety inspection in your home at least twice a year.

- Make the home inspection a family project and include everyone in the process.
- Utilize the Home Fire Safety Inspection Checklists provided by the department to complete the inspection of your home.
- The inspection should be performed twice a year: once in the spring and once in the fall.
- Once deficiencies are identified, make it a priority to correct them immediately.



Five Quick Tips

1. Schedule a fire safety inspection and include the entire family in the process.
2. Make corrections as soon as problems are found, and assign unresolved tasks to family members to be completed within two weeks.
3. Do not overlook areas such as crawl spaces, porches and attics.
4. Speak to your home owner's insurance agent to check for potential savings due to your safety efforts.
5. DO NOT PROCRASTINATE.

Simple Steps for Your Home Fire Inspection

- Be prepared with several items to assist you, including: stepladder, screwdrivers, pliers, batteries, gloves, eye protection and checklist
- Start on the lowest level of your home and work up. Finish by inspecting the outside and garage areas.
- If you can make corrections immediately, do so. If not, make notes on what will be required to make corrections, and assign the tasks to a specific family member for completion.
- If corrections are beyond your expertise, hire a professional to make them.
- Maintain all inspection records to refer to during subsequent inspections.

Critical Tasks for Each Inspection

- Test your Smoke Alarms, replace the battery and replace the alarm if it is over 10 years old.
- After DISCONNECTING THE POWER - Remove the cover of all vent fans and dust the motor, blades, and cover.
- Change all furnace filters.
- Move dryer, and thoroughly clean behind and underneath. Also clean out the dryer vent pipe and exhaust plate on the outside wall.
- Remove all accumulated clutter, newspapers, clothing and trash.

A two-hour time investment can protect your family for six months